

	Report	Technology
---	---------------	-------------------

Title: Technical Criteria For Procurement
of Split Meter Readyboard Retrofit

Unique Identifier:

Alternative Reference Number: **N/A**

Area of Applicability: **Engineering**

Documentation Type: **Report**


Revision: **1**

Total Pages: **5**

Next Review Date: **N/A**

Disclosure Classification: **CONTROLLED
DISCLOSURE**

Compiled by




Masithembe Ngcwama
Senior Technician

Supported by



Jutas Maudu
Senior Engineer

Authorised by



Stephen Nkwane
SI Manager-GOU

Date: ...2019/02/21.....

Date: 22/02/2019

Date: 22/02/2019

Contents

1. INTRODUCTION.....	2
2. SUPPORTING CLAUSES.....	2
2.1.1 Scope	2
2.1.2 Purpose	2
2.1.3 Applicability	3
2.2 NORMATIVE/INFORMATIVE REFERENCES	3
2.2.1 Normative	3
2.2.2 Informative	3
2.3 DEFINITIONS	3
2.3.1 General	3
2.3.2 Disclosure classification	3
2.4 ABBREVIATIONS.....	3
3. TENDER REQUIREMENTS.....	4
3.1 IMPORTANT INFORMATION	4
3.2 LIST OF RETURNABLE	4
3.2.1 Technical test reports	4
3.2.2 :Manufactures Drawings.....	4
3.2.3 Retrofit Sample	4
4. TECHNICAL EVALUATION CRITERIA.....	4
4.1 TECHNICAL EVALUATION STAGES	4
4.2 SCORING	4
5. REVISION HISTORY	4
ANNEX A: SCORING	5
PROCUREMENT OF SPLIT METER READYBOARD RETROFIT	ERROR! BOOKMARK NOT DEFINED.

1. INTRODUCTION

This document provides an overview of Eskom's Gauteng Operating Unit technical evaluation criteria to be used when evaluating the tender submissions for the supply of Split Meter Readyboard Retrofit.

2. SUPPORTING CLAUSES

2.1.1 Scope

The document contains the technical requirements and returnable for tenderers of the following product (s) which currently are not on a National Contract and/or not on LAP.

Eskom Standard	SAP No.	Description	Eskom Drawing Number
Buyers Guide	0643155	SPLIT METER READYBOARD RETROFIT	D-DT- 3171

2.1.2 Purpose

The aim of the document is to formalize the requirements that should be met by the supplier for the product (s) requested.

2.1.3 Applicability

This document shall apply throughout Eskom Gauteng Operating Unit.

2.2 NORMATIVE/INFORMATIVE REFERENCES

Parties using this document shall apply the most recent edition of the documents listed in the following paragraphs.

2.2.1 Normative

- [1] ISO 9001, Quality Management Systems.
- [2] Eskom Drawing No. **D-DT- 3171**
- [3] 240-75659896: Specification For Small Power Distribution Unit For Split Prepayment Metering (Ready Board) For Single-Phase 230v Service Connections Standard

2.2.2 Informative

N/A

2.3 DEFINITIONS

2.3.1 General

Definition	Description
Tender	A tender refers to an open or closed competitive request for quotations / prices against a clearly defined scope / specification.

2.3.2 Disclosure classification

Controlled disclosure: controlled disclosure to external parties (either enforced by law, or discretionary).

2.4 ABBREVIATIONS

Abbreviation	Description
ISO	International Standard Organisation
LAP	List of Accepted Products
GOU	Gauteng Operating Unit
SI	Standards Implementation Department

3. TENDER REQUIREMENTS

3.1 IMPORTANT INFORMATION

The following shall be submitted by the tenderer. Please note that if any of the requested documentation is omitted (i.e. not submitted); the tender application may be discarded / disqualified without requesting tenderer to submit outstanding documentation. Eskom will treat all documents submitted by the tender as **confidential**. Eskom may request to conduct factory visits, witnessing and or submission of samples. Eskom reserves the right to witness any or all of these tests.

3.2 LIST OF RETURNABLE

3.2.1 Technical test reports

3.2.2 :Manufactures Drawings

3.2.3 Retrofit Sample

4. TECHNICAL EVALUATION CRITERIA

4.1 TECHNICAL EVALUATION STAGES

This will be a desktop evaluation of the mandatory requirements. Products will be evaluated individually. The tenderer needs to obtain a **weighted score of 100%** in order to pass the Evaluation.

The table below shows the scoring that will be applied:

Item	Description	Weight
Mandatory Criteria (Evaluation Stage 1)		
1	Annexure - Schedules A&B (<i>Zero mark for non-compliances or blank fields</i>)	70%
2	Drawings	30%

4.2 SCORING

Requirements shall be scored as shown on table below:

Criteria	Score
Compliant	5
Non-compliant	0

5. REVISION HISTORY

Date	Revision	Compiler	Remarks
Feb 2019	1	Jutas Maudu	First Issue

ANNEX A: SCORING

PROCUREMENT OF SPLIT METER READYBOARD RETROFIT

Enquiry number: Spec. ref no D-DT- 3171

Supplier Name:..... Date:.....

Manufacturer Name:.....

Technical Schedules A and B

Schedule 1 – Procurement of SPLIT METER READYBOARD RETROFIT

Schedule A: Purchaser's specific requirements(Eskom)

Schedule B: Guarantees and Particulars of equipment offered (Supplier)

No.	DESCRIPTION	SCHEDULE A	SCHEDULE B	SCORE
1	KIT TYPE – SAMPLE PROVIDED	SPLIT METER READYBOARD RETROFIT		
2	APPLICATION	SMALL POWER DISTRIBUTION UNIT FOR SPLIT PREPAYMENT METER (RETROFIT)		
3	SUITABLE TO FIT ONLY INTO ECU STANDARD PASSIVE UNIT BASE	63 A EARTH LEAKAGE UNIT AND 20 A CIRCUIT BREAKER		
4	COMPRISING	COMPLY		
5	DIMENSIONS	WD 148 X LG 260 MM		
6	MOUNTING TYPE	SCREWS		
7	SHAPE	RECTANGULAR		
8	BLADE MATERIAL	2MM COPPER SHEET CONNECTOR BLADE TOLERANCE OF APPROXIMATELY 1MM		
9	FINISH MATERIAL	NICKEL		
10	PLATE TYPE	3-7 MICRON		
11	COVER MATERIAL	POLYCARBONATE (MIN V1)		
12	COLOUR FOR READYBOARD COVER	IVORY		
13	SUPPLIED WITH DRILLED HOLES (KNOCKOUTS NOT HOLES)FOR KEYPAD MOUNTING	COMPLY		
14	READYBOARD RETROFIT TO BE SUPPLIED WITH AN ABRIDGED COC	COMPLY		
15	MANUFACTURER DRAWING	COMPLY		
16	DANGER SIGN SHOWN ON THE COVER SHOWN(OUTSIDE)	COMPLY		
	COVER CLEARLY MARKED "FOR ECU USE ONLY"	-----		
17	TESTS	GLOWIRE AND PROOF MUST BE SUBMITTED		

Declaration that the scheduled has been completed by us **(Sign or insert company Stamp).**

Signed by : _____
(Full Name)

Signature : _____