

**Technical Schedules A and B for
DDT-3080 - SIDE GROOVE TIE**

NB. UNIQUE SCHEDULES ARE TO BE COMPLETED PER SAP NUMBER LISTED BELOW

NB. SUPPLIERS TO CONFIRM ADHERENCE TO THE LATEST PUBLISHED REVISION OF ALL APPLICABLE ESKOM DRAWINGS

SAP Number	Technical Description
402657	TIE,SIDE GRVE B/MINK INLAND D3080
168374	TIE,SIDE GRVE B/FOX INLAND D3080
168519	TIE,SIDE GRVE B/HARE INLAND D3080
168563	TIE,SIDE GRVE B/MAGPIE INLAND D3080
168697	TIE,SIDE GRVE B/HORNET INLAND D3080
168878	TIE,SIDE GRVE B/SQUIRREL INLAND D3080
180581	TIE,SIDE GRVE B/ACACIA+SQUIR COAST D3080
180582	TIE,SIDE GRVE B/MAGPIE COAST D3080
180583	TIE,SIDE GRVE B/FOX/35 COAST D3080
180584	TIE,SIDE GRVE B/MINK/PINE COAST D3080
180585	TIE,SIDE GRVE B/HARE/OAK COAST D3080
210442	TIE,SIDE GRVE B/CHICADEE INLAND D3080
210443	TIE,SIDE GRVE B/KINGBIRD INLAND D3080

Schedule A: Purchasers specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

1	2	3	4
Item	Description	Schedule A	Schedule B
1	Product Information		
1.1	• Purchasing details		
1.1.1	Eskom SAP No	Select SAP number from list above	xxxxxxxxxx
1.1.2	Manufacturer	Manufacturer name	xxxxxxxxxx
1.1.3	Manufacturer's Product Code	Specify Code	xxxxxxxxxx
1.1.4	Manufacturer's Drawing number & Revision number	Specify No and Rev	xxxxxxxxxx
1.1.5	Manufacturer's physical unique identifier indelibly marked. - All products must be properly identified by a durable label that cannot be torn or pulled off for 12 months after purchased to indicate manufacturer, size/stranding of conductor, batch number and catalogue number. - The label shall be durable enough to ensure that it remains in place and is legible up to at least 12 months after installation.	240-75883388	YES
1.1.6	All supplied hardware must be properly identified by a durable paint in the correct colour code that will remain for a minimum of 5 years after purchase and installed outdoors.	240-75883844	YES
1.1.7	• Compliance to Eskom Buyer's Guide Drawings		
1.1.7.1	SIDE GROOVE TIE - For use on type F-neck insulators	Eskom DDT-3080	YES
1.1.7.2	SIDE GROOVE TIE - For use on conductor as per SAP number	Eskom DDT-3080	YES

Enquiry No.: _____

Date: ____/____/____

Tenderers Name: _____

A & B Schedule

1.1.7.3		SIDE GROOVE TIE - Includes neoprene or equivalent padding	Eskom DDT-3080	YES	
1.1.7.4		SIDE GROOVE TIE - Colour Code as per SAP number	Eskom DDT-3080	YES	
1.1.8		Item sample required, upon request from Eskom (As per the Technical Criteria Document)		YES	xxxxxxxxxx
1.2	•	Mechanical Properties			
1.2.1		Material - Side Groove Tie		ALUMINIUM ALLOY OR STAINLESS STEEL OR GALVANISED STEEL	
1.2.2		Has the steel been hot dip galvanized as per SANS 121		YES	
1.2.3		Material - Side Groove Tie - Grit Chemically inert grit shall be applied where applicable by an appropriate method of adhesion to the inner surfaces of the helical fittings. Type & quality of grit shall not be damaging to the product or conductor		YES	
1.2.4		Material - Side Groove Tie - Padding		Elastomer mouldings or cushion pads or Neoprene	
2		Documentation (to be submitted with tender)			
		Note: All documentation to also be provided in electronic format.			
2.1	•	General			
2.1.1		Approved Manufacturer Drawings showing markings and dimensions	1 Set submitted	YES	
2.2	•	Test Reports (where applicable)			Required
2.2.1		Has the relevant signed mandatory test schedule been submitted.	Signed Test Schedule Submitted	YES	
3		Packaging			
3.1		Packaging as per 240-75883388 section 5		YES	
3.2		Installation instructions provided in packaging		YES	

Deviations to any of the stated requirements are to be captured on the Deviation Schedule.

SUPPLIER SIGNATURES

Name (Print)

Company name

Sign

Date